



## CERTIFICATE OF ANALYSIS

**REPORTED TO** The Water Guy  
600 Industrial Road 1, Unit #12 & #13  
CRANBROOK, BC V1C 3R1

**ATTENTION** Al Schaeffer

**PO NUMBER**

**PROJECT** IHA New Sources

**PROJECT INFO**

**WORK ORDER** 20K2450

**RECEIVED / TEMP** 2020-11-23 13:30 / 17°C

**REPORTED** 2020-11-30 15:48

**COC NUMBER** No Number

### Introduction:

CARO Analytical Services is a testing laboratory full of smart, engaged scientists driven to make the world a safer and healthier place. Through our clients' projects we become an essential element for a better world. We employ methods conducted in accordance with recognized professional standards using accepted testing methodologies and quality control efforts. CARO is accredited by the Canadian Association for Laboratories Accreditation (CALA) to ISO/IEC 17025:2017 for specific tests listed in the scope of accreditation approved by CALA.

#### *Big Picture Sidekicks*



You know that the sample you collected after snowshoeing to site, digging 5 meters, and racing to get it on a plane so you can submit it to the lab for time sensitive results needed to make important and expensive decisions (whew) is VERY important. We know that too.

#### *We've Got Chemistry*



It's simple. We figure the more you enjoy working with our fun and engaged team members; the more likely you are to give us continued opportunities to support you.

#### *Ahead of the Curve*



Through research, regulation knowledge, and instrumentation, we are your analytical centre for the technical knowledge you need, BEFORE you need it, so you can stay up to date and in the know.


If you have any questions or concerns, please contact me at [teamcaro@caro.ca](mailto:teamcaro@caro.ca)

### Authorized By:

Team CARO  
Client Service Representative

1-888-311-8846 | [www.caro.ca](http://www.caro.ca)

#110 4011 Viking Way Richmond, BC V6V 2K9 | #102 3677 Highway 97N Kelowna, BC V1X 5C3 | 17225 109 Avenue Edmonton, AB T5S 1H7




# TEST RESULTS

**REPORTED TO PROJECT** The Water Guy  
IHA New Sources

**WORK ORDER REPORTED** 20K2450  
2020-11-30 15:48

Analyte	Result	Guideline	RL Units	Analyzed	Qualifier
<b>WL18112020 (20K2450-01)   Matrix: Water   Sampled: 2020-11-22 12:00</b>					
<b>Anions</b>					
Chloride	8.09	AO ≤ 250	0.10 mg/L	2020-11-24	
Fluoride	0.22	MAC = 1.5	0.10 mg/L	2020-11-24	
Nitrate (as N)	< 0.010	MAC = 10	0.010 mg/L	2020-11-24	
Nitrite (as N)	< 0.010	MAC = 1	0.010 mg/L	2020-11-24	
Sulfate	49.9	AO ≤ 500	1.0 mg/L	2020-11-24	
<b>Calculated Parameters</b>					
Hardness, Total (as CaCO <sub>3</sub> )	237	None Required	0.500 mg/L	N/A	
Langelier Index	0.6	N/A	-5.0	2020-11-30	
Nitrogen, Organic	0.450	N/A	0.0500 mg/L	N/A	
Solids, Total Dissolved	273	AO ≤ 500	1.00 mg/L	N/A	
<b>General Parameters</b>					
Alkalinity, Total (as CaCO <sub>3</sub> )	216	N/A	1.0 mg/L	2020-11-27	
Alkalinity, Phenolphthalein (as CaCO <sub>3</sub> )	3.8	N/A	1.0 mg/L	2020-11-27	
Alkalinity, Bicarbonate (as CaCO <sub>3</sub> )	209	N/A	1.0 mg/L	2020-11-27	
Alkalinity, Carbonate (as CaCO <sub>3</sub> )	7.6	N/A	1.0 mg/L	2020-11-27	
Alkalinity, Hydroxide (as CaCO <sub>3</sub> )	< 1.0	N/A	1.0 mg/L	2020-11-27	
Ammonia, Total (as N)	< 0.050	None Required	0.050 mg/L	2020-11-25	
Carbon, Total Organic	3.34	N/A	0.50 mg/L	2020-11-25	
Colour, True	< 5.0	AO ≤ 15	5.0 CU	2020-11-26	HT1
Conductivity (EC)	473	N/A	2.0 μS/cm	2020-11-27	
Cyanide, Total	< 0.0020	MAC = 0.2	0.0020 mg/L	2020-11-30	
Nitrogen, Total Kjeldahl	0.450	N/A	0.050 mg/L	2020-11-26	
pH	8.37	7.0-10.5	0.10 pH units	2020-11-27	HT2
Phosphorus, Total (as P)	0.0223	N/A	0.0050 mg/L	2020-11-25	
Sulfide, Total	< 0.020	AO ≤ 0.05	0.020 mg/L	2020-11-25	
Temperature, at pH	19.5	N/A	°C	2020-11-27	HT2
Turbidity	1.61	OG < 1	0.10 NTU	2020-11-24	
UV Transmittance @ 254 nm - Unfiltered	89.5	N/A	0.10 % T	2020-11-24	
<b>Microbiological Parameters</b>					
Coliforms, Total	39	MAC = 0	1 CFU/100 mL	2020-11-24	HT3
Background Colonies	23	N/A	1 CFU/100 mL	2020-11-24	HT1
E. coli	< 1	MAC = 0	1 CFU/100 mL	2020-11-24	HT3
<b>Total Metals</b>					
Aluminum, total	0.0085	OG < 0.1	0.0050 mg/L	2020-11-27	
Antimony, total	< 0.00020	MAC = 0.006	0.00020 mg/L	2020-11-27	
Arsenic, total	0.00117	MAC = 0.01	0.00050 mg/L	2020-11-27	
Barium, total	0.0305	MAC = 2	0.0050 mg/L	2020-11-27	
Boron, total	< 0.0500	MAC = 5	0.0500 mg/L	2020-11-27	
Cadmium, total	< 0.000010	MAC = 0.005	0.000010 mg/L	2020-11-27	
Calcium, total	23.2	None Required	0.20 mg/L	2020-11-27	



## TEST RESULTS


**REPORTED TO PROJECT** The Water Guy  
IHA New Sources

**WORK ORDER REPORTED** 20K2450  
2020-11-30 15:48

Analyte	Result	Guideline	RL Units	Analyzed	Qualifier
<b>WL18112020 (20K2450-01)   Matrix: Water   Sampled: 2020-11-22 12:00, Continued</b>					
<i>Total Metals, Continued</i>					
Chromium, total	< 0.00050	MAC = 0.05	0.00050 mg/L	2020-11-27	
Cobalt, total	< 0.00010	N/A	0.00010 mg/L	2020-11-27	
Copper, total	< 0.00040	MAC = 2	0.00040 mg/L	2020-11-27	
Iron, total	<b>0.021</b>	AO ≤ 0.3	0.010 mg/L	2020-11-27	
Lead, total	< 0.00020	MAC = 0.005	0.00020 mg/L	2020-11-27	
Magnesium, total	<b>43.5</b>	None Required	0.010 mg/L	2020-11-27	
Manganese, total	<b>0.00404</b>	MAC = 0.12	0.00020 mg/L	2020-11-27	
Mercury, total	< 0.000010	MAC = 0.001	0.000010 mg/L	2020-11-27	
Molybdenum, total	<b>0.00065</b>	N/A	0.00010 mg/L	2020-11-27	
Nickel, total	< 0.00040	N/A	0.00040 mg/L	2020-11-27	
Potassium, total	<b>2.05</b>	N/A	0.10 mg/L	2020-11-27	
Selenium, total	< 0.00050	MAC = 0.05	0.00050 mg/L	2020-11-27	
Sodium, total	<b>13.8</b>	AO ≤ 200	0.10 mg/L	2020-11-27	
Strontium, total	<b>0.118</b>	7	0.0010 mg/L	2020-11-27	
Uranium, total	<b>0.00169</b>	MAC = 0.02	0.000020 mg/L	2020-11-27	
Zinc, total	< 0.0040	AO ≤ 5	0.0040 mg/L	2020-11-27	

**Sample Qualifiers:**

- HT1 The sample was prepared and/or analyzed past the recommended holding time.
- HT2 The 15 minute recommended holding time (from sampling to analysis) has been exceeded - field analysis is recommended.
- HT3 Microbiological analysis was initiated beyond the maximum holding time of 30 hours. Results may not be valid.



## APPENDIX 1: SUPPORTING INFORMATION

**REPORTED TO PROJECT** The Water Guy  
IHA New Sources


**WORK ORDER REPORTED** 20K2450  
2020-11-30 15:48

Analysis Description	Method Ref.	Technique	Accredited	Location
Alkalinity in Water	SM 2320 B* (2017)	Titration with H2SO4	✓	Kelowna
Ammonia, Total in Water	SM 4500-NH3 G* (2017)	Automated Colorimetry (Phenate)	✓	Kelowna
Anions in Water	SM 4110 B (2017)	Ion Chromatography	✓	Kelowna
Carbon, Total Organic in Water	SM 5310 B (2017)	Combustion, Infrared CO2 Detection	✓	Kelowna
Coliforms, Total in Water	SM 9222* (2017)	Membrane Filtration / Chromocult Agar	✓	Kelowna
Colour, True in Water	SM 2120 C (2017)	Spectrophotometry (456 nm)	✓	Kelowna
Conductivity in Water	SM 2510 B (2017)	Conductivity Meter	✓	Kelowna
Cyanide, SAD in Water	ASTM D7511-12	Flow Injection with In-Line UV Digestion and Amperometry	✓	Kelowna
E. coli in Water	SM 9222* (2017)	Membrane Filtration / Chromocult Agar	✓	Kelowna
Hardness in Water	SM 2340 B* (2017)	Calculation: 2.497 [total Ca] + 4.118 [total Mg] (Est)	✓	N/A
Langelier Index in Water	SM 2330 B (2017)	Calculation		N/A
Mercury, total in Water	EPA 245.7*	BrCl2 Oxidation / Cold Vapor Atomic Fluorescence Spectrometry (CVAFS)	✓	Richmond
Nitrogen, Total Kjeldahl in Water	SM 4500-Norg D* (2017)	Block Digestion and Flow Injection Analysis	✓	Kelowna
pH in Water	SM 4500-H+ B (2017)	Electrometry	✓	Kelowna
Phosphorus, Total in Water	SM 4500-P B.5* (2011) / SM 4500-P F (2017)	Persulfate Digestion / Automated Colorimetry (Ascorbic Acid)	✓	Kelowna
Solids, Total Dissolved in Water	SM 1030 E (2017)	SM 1030 E (2011)		N/A
Sulfide, Total in Water	SM 4500-S2 D* (2017)	Colorimetry (Methylene Blue)	✓	Edmonton
Total Metals in Water	EPA 200.2 / EPA 6020B	HNO3+HCl Hot Block Digestion / Inductively Coupled Plasma-Mass Spectroscopy (ICP-MS)	✓	Richmond
Transmittance at 254 nm - Unfiltered in Water	SM 5910 B* (2017)	Ultraviolet Absorption	✓	Kelowna
Turbidity in Water	SM 2130 B (2017)	Nephelometry	✓	Kelowna

Note: An asterisk in the Method Reference indicates that the CARO method has been modified from the reference method

### Glossary of Terms:

RL	Reporting Limit (default)
% T	Percent Transmittance
<	Less than the specified Reporting Limit (RL) - the actual RL may be higher than the default RL due to various factors
°C	Degrees Celcius
AO	Aesthetic Objective
CFU/100 mL	Colony Forming Units per 100 millilitres
CU	Colour Units (referenced against a platinum cobalt standard)
MAC	Maximum Acceptable Concentration (health based)
mg/L	Milligrams per litre
NTU	Nephelometric Turbidity Units
OG	Operational Guideline (treated water)
pH units	pH < 7 = acidic, pH > 7 = basic
µS/cm	Microsiemens per centimetre
ASTM	ASTM International Test Methods
EPA	United States Environmental Protection Agency Test Methods
SM	Standard Methods for the Examination of Water and Wastewater, American Public Health Association



## APPENDIX 1: SUPPORTING INFORMATION

**REPORTED TO** The Water Guy  
**PROJECT** IHA New Sources

**WORK ORDER** 20K2450  
**REPORTED** 2020-11-30 15:48


**General Comments:**

The results in this report apply to the samples analyzed in accordance with the Chain of Custody document. This analytical report must be reproduced in its entirety. CARO is not responsible for any loss or damage resulting directly or indirectly from error or omission in the conduct of testing. Liability is limited to the cost of analysis. Samples will be disposed of 30 days after the test report has been issued or once samples expire, whichever comes first. Longer hold is possible if agreed to in writing. The quality control (QC) data is available upon request

Results in **Bold** indicate values that are above CARO's method reporting limits. Any results that are above regulatory limits are highlighted **red**. Please note that results will only be highlighted red if the regulatory limits are included on the CARO report. Any Bold and/or highlighted results do not take into account method uncertainty. If you would like method uncertainty or regulatory limits to be included on your report, please contact your Account Manager: [teamcaro@caro.ca](mailto:teamcaro@caro.ca)

*Please note any regulatory guidelines applied to this report are added as a convenience to the client, at their request, to help provide some initial context to analytical results obtained. Although CARO makes every effort to ensure accuracy of the associated regulatory guideline(s) applied, the guidelines applied cannot be assumed to be correct due to a variety of factors and as such CARO Analytical Services assumes no liability or responsibility for the use of those guidelines to make any decisions. The original source of the regulation should be verified and a review of the guideline(s) should be validated as correct in order to make any decisions arising from the comparison of the analytical data obtained to the relevant regulatory guideline for one's particular circumstances. Further, CARO Analytical Services assumes no liability or responsibility for any loss attributed from the use of these guidelines in any way.*





\* 2 0 K 2 4 5 0 \*



CARO.ca 1-888-311-8846

#110-4011 Viking Way, Richmond, BC V6V 2K9
#102-3677 Highway 97N, Kelowna, BC V1X 5C3
17225 109 Avenue NW, Edmonton, AB T5S 1H7

Caring About Results, Obviously.

CHAIN OF CUSTODY RECORD COC# PAGE OF

REPORT TO: COMPANY: THE WATER GUY
ADDRESS: 12-600 INDUSTRIAL ROAD 1
CRANBROOK BC
CONTACT: AL SCHAEFFER
TEL/FAX: 250-489-4000
DELIVERY METHOD: EMAIL [X] MAIL [ ] OTHER\* [ ]
DATA FORMAT: EXCEL [ ] WATERTRAX [ ] ESdat [ ]
EMAIL 1: SERVICE@THEWATERGUY.CA

INVOICE TO: SAME AS REPORT TO [X]
COMPANY:
ADDRESS:
CONTACT:
TEL/FAX:
DELIVERY METHOD: EMAIL [ ] MAIL [ ] OTHER\* [ ]
EMAIL 1:
EMAIL 2:
EMAIL 3:
PO #:

RELINQUISHED BY: DATE: RECEIVED BY: DATE: 11/23
TIME: 1:30
TURNAROUND TIME REQUESTED: Routine: (5-7 Days) [X]
Rush: 1 Day\* [ ] 2 Day\* [ ] 3 Day\* [ ]
REGULATORY APPLICATION: Canadian Drinking Water Quality [ ] BC WQG [ ] BC HWR [ ]
BC CSR Soil: WL [ ] AL [ ] PL [ ] RL-LD [ ] RL-HD [ ] CL [ ] IL [ ]
BC CSR Water: AW [ ] IW [ ] LW [ ] DW [ ]
\*Contact Lab To Confirm. Surcharge May Apply
PROJECT NUMBER / INFO:
A: Biohazard D: Asbestos G: Strong Odour
B: Cyanide E: Heavy Metals H: High Contamination
C: PCBs F: Flammable I: Other (please specify\*)

ANALYSES REQUESTED:

\*\* If you would like to sign up for ClientConnect and/or EnviroChain, CARO's online service offerings, please check here: [ ]

Table with columns: SAMPLED BY, MATRIX (DRINKING WATER, OTHER WATER, SOIL, OTHER), SAMPLING (DATE, TIME), COMMENTS, and various chemical analysis checkboxes (BTEX, VOC, EPH, PAH, PHENOLS, PCB, PESTICIDES, METALS, etc.). Includes handwritten sample ID WL18112020 and analysis notes.

SHIPPING INSTRUCTIONS: Return Cooler(s) [ ]
Supplies Needed:

SAMPLE RETENTION: 30 Days (default) [ ]
60 Days [ ] 90 Days [ ]
Other (surcharges will apply):

\* OTHER INSTRUCTIONS: One Complete - BC Interior Health - Comprehensive -ensive set for New water Sources.
If you would like to talk to a real live Scientist about your project requirements, please check here: [ ]

SAMPLE RECEIPT CONDITION: COOLER 1 (°C): 17.0 ICE: Y [ ] N [ ]
COOLER 2 (°C): ICE: Y [ ] N [ ]
COOLER 3 (°C): ICE: Y [ ] N [ ]
CUSTODY SEALS INTACT: NA [ ] Y [ ] N [ ]